STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155733	A. BUILDING **01** B. WING _____	R **11/05/2014**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
COLONIAL NURSING HOME	**119 N INDIANA AVE** **CROWN POINT, IN 46307**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post survey Revisit to the Life Safety Code Recertification and State Licensure Survey conducted on 09/22/14 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 11/05/14 Facility Number: 000360 Provider Number: 155733 AIM Number: 100290370 Surveyor: Dennis Austill, Life Safety Code Specialist At this PSR survey, Colonial Nursing Home was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This facility is a two story fully sprinklered building determined to be Type V (111) construction with a lower level located in the basement with additions and updates made prior to March 1, 2003. The facility has a fire alarm system with hard wired smoke detection in the corridors, spaces open to the corridors, and C hall first floor resident rooms. All other resident rooms are equipped with battery powered smoke detectors. The facility has the capacity for 55 and had a census of 46 at the time of this survey. All areas where residents have customary access	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155733	A. BUILDING **01** B. WING _____	R **11/05/2014**

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
COLONIAL NURSING HOME	**119 N INDIANA AVE** **CROWN POINT, IN 46307**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 and areas providing facility services were sprinklered. Quality Review by Lex Brashear, Life Safety Code Specialist-Medical Surveyor on 11/10/14.	{K 000}		